



## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 103546003  
**Gauge application** : Incoming inspection  
**Standard of thread** : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996  
**Type of gauge** : GO/NOT GO thread plug gauge  
**Thread designation** : M 4x0.5-6H LH  
**Pitch** : 0,5000 mm  
**Measuring method** : Three wires method  
**Wire diameter** : 0,2901 mm  
**second wire diameter** : 0,2901 mm  
**Measuring force** : 3,80 N  
**Measurement traceability** : Mahr 828 Nr.31  
**Measurement traceability** : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 4,0150 mm	3,8885 mm
Major diameter min.	: 3,9970 mm	3,8705 mm
Pitch diameter max.	: 3,6855 mm	3,7840 mm
Pitch diameter min.	: 3,6765 mm	3,7750 mm
Minor diameter max.	: 3,3870 mm	3,3870 mm

### Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	3,6802	-

### Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	3,7781	-

Valuation: usable

Operator:

  
(Lehmann)

Date: 08.01.2018

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.