

## CALIBRATION CERTIFICATE

Customer : 0155600  
Identification number : 113791013  
Gauge application : Incoming inspection  
Standard of thread : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996  
Type of gauge : GO thread ring gauge (solid)  
Thread designation : M 20x2.5-6h  
Pitch : 2,5000 mm  
Measuring method : Measure with IAC Master Scanner  
Measurement traceability : IAC XLP-C 300 Nr.579  
Measurement traceability : Set of setting rings ID 8138 101590 D-K-15089-01-01 2016-09

**Gauge nominal values**


Major diameter min. : 20,1910 mm  
Pitch diameter max. : 18,3770 mm  
Pitch diameter min. : 18,3590 mm  
Minor diameter max. : 17,3030 mm  
Minor diameter min. : 17,2850 mm

**Measuring values Pitch diameter**

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	18,3700	-

**Valuation: usable**

Operator:

  
(Eha)

Date: 24.10.2018

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:**  $(20 \pm 1) ^\circ\text{C}$ . **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.