

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 113858050
Gauge application : Incoming inspection
Standard of thread : Pipe threads according to ISO 228:2003
Type of gauge : NOGO thread plug gauge
Thread designation : G 1 1/4
Pitch : 2,3090 mm
Measuring method : Three wires method
Wire diameter : 1,3023 mm
Measuring force : 9,20 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values


Major diameter max. : 41,0910 mm
Major diameter min. : 41,0670 mm
Pitch diameter max. : 40,6230 mm
Pitch diameter min. : 40,6110 mm
Minor diameter max. : 38,7720 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	40,6186	-

Valuation: usable

Operator:


(Nau)

Date: 26.03.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.