

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 114407219
Gauge application : Incoming inspection
Standard of thread : Pipe threads according to ISO 228:2003
Type of gauge : GO thread ring gauge (solid)
Thread designation : G 1/4 A
Pitch : 1,3370 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC MSXP 100x25 Nr.551
Measurement traceability : Set of setting rings ID 8138 101590 D-K-15089-01-01 2016-09

Gauge nominal values

Major diameter min. : 13,1570 mm
 Pitch diameter max. : 12,3070 mm
 Pitch diameter min. : 12,2910 mm
 Minor diameter max. : 11,4450 mm
 Minor diameter min. : 11,4290 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	12,2995	-

Valuation: usable

Operator:

(Nau)

Date: 11.09.2018

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

Ref.temp: $(20 \pm 1) \text{ }^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.