

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 115231007
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996
Type of gauge : NO GO thread ring gauge (solid)
Thread designation : M 2.5x0.45-6h
Pitch : 0,4500 mm
Measuring method : Inspection with checking or setting gauge

Gauge nominal values

Major diameter min. : 2,5070 mm
 Pitch diameter max. : 2,1370 mm
 Pitch diameter min. : 2,1270 mm
 Minor diameter max. : 2,0520 mm
 Minor diameter min. : 2,0320 mm

Checking the Pitch diameter with check plugs

| Check plug | Check plug ID | PitchØ nominal value [mm] | PitchØ actual value [mm] |
|-------------------|---------------|---------------------------|--------------------------|
| GO check plug | 8 | 2,1200 ±0,0035 | 2,1200 |
| NOT GO check plug | 22 | 2,1370 ±0,0035 | 2,1390 |

Valuation: usable

Operator:

(Salvaggio)

Date: 07.06.2018

Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.