

## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 115934001  
**Gauge application** : Incoming inspection  
**Standard of thread** : ASA B2.2-1960 (NPTF, PTF)  
**Type of gauge** : Taper full form thread ring gauge  
**Thread designation** : 3/8 - 18 NPTF L1  
**Pitch** : 1,4110 mm  
**Measuring method** : Measure with IAC Master Scanner  
**Measurement traceability** :

### Gauge nominal values

Major diameter min. : 16,9588 mm  
 Pitch diameter max. : 15,9311 mm  
 Pitch diameter min. : 15,9210 mm  
 Minor diameter max. : 15,2830 mm  
 Minor diameter min. : 15,2680 mm  
 Length L1 : 6,0960 mm  
 Gauge plane : 0,0000 mm

### Measuring values Pitch diameter

Gauge plane IAC [mm]	Axial section	PitchØ [mm]	Out of tolerance [mm]
0,0000	0° Degree	15,9236	-

**Valuation: usable**

Operator:

  
(Sahan)

Date: 19.02.2018

**Uncertainty of measurement:**  $U = 2,5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability. **Ref.temp:**  $(20 \pm 1) ^\circ\text{C}$ .  
**Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.