



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 9021330-310 (117678005)
Gauge application : Incoming inspection
Standard of thread : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2
Type of gauge : GO thread plug gauge
Thread designation : 5/16 - 32 UNEF -2B
Pitch : 0,7940 mm
Measuring method : Three wires method
Wire diameter : 0,4557 mm
Measuring force : 4,00 N
Measurement traceability : Mahr 828 Nr.22
Measurement traceability : single gauge ID 316275 033416 D-K-15048-01-00 2020-06

Gauge nominal values


Major diameter max. : 7,9502 mm
 Major diameter min. : 7,9375 mm
 Pitch diameter max. : 7,4295 mm
 Pitch diameter min. : 7,4219 mm
 Minor diameter max. : 6,9063 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	7,4277	-

Valuation: usable

Operator:


(Gjigjani)

Date: 28.01.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.