

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 118455080
Gauge application : Incoming inspection
Standard of thread : Pipe threads acc. to ANSI/ASME B1.20.1-2013 (NPT)
Type of gauge : Taper full form thread ring gauge
Thread designation : 1/4 - 18 NPT
Pitch : 1,4112 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC XLP-C 300 Nr.579
Measurement traceability : Set of setting rings ID 8138 101590 D-K-15089-01-01 2016-09

Gauge nominal values

Major diameter min. : 13,5202 mm
Pitch diameter max. : 12,4925 mm
Pitch diameter min. : 12,4823 mm
Minor diameter max. : 11,5882 mm
Minor diameter min. : 11,5730 mm
Length L1 : 5,7861 mm
Gauge plane : 0,0000 mm

Measuring values Pitch diameter

Gauge plane IAC [mm]	Axial section	PitchØ [mm]	Out of tolerance [mm]
0,0000	0° Degree	12,4873	-

Valuation: usable

Operator: *Buckenmayer* (Buckenmayer) Date: 20.03.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability. **Ref.temp:** $(20 \pm 1) ^\circ\text{C}$.
Inspection requirement: The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.