

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 119142001
Gauge application : Incoming inspection
Standard of thread : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2
Type of gauge : NO GO thread ring gauge (solid)
Thread designation : 17/32 - 24 UNS -2A
Pitch : 1,0580 mm
Measuring method : "Three balls" method (using T-probe)
Used ball diameter : 0,6145 mm
Constant of T-shaped probe : 4,0361 mm
Measurement traceability : Mahr 828 ID 381
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values

Major diameter min. : 13,4645 mm
Pitch diameter max. : 12,6848 mm
Pitch diameter min. : 12,6771 mm
Minor diameter max. : 12,4612 mm
Minor diameter min. : 12,4485 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	12,6789	-

Valuation: usable

Operator:

(Salvaggio)

Date: 21.08.2018

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.