

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 119542019
Gauge application : Incoming inspection
Standard of thread : Metric thread inserts acc. to DIN 8140:1999/2017
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : EG M 2x0.4-6H mod
Pitch : 0,4000 mm
Measuring method : Three wires method
Wire diameter : 0,2314 mm
second wire diameter : 0,2314 mm
Measuring force : 3,60 N
Measurement traceability : Mahr 828 Nr.22
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 2,5290 mm	2,4020 mm
Major diameter min.	: 2,5150 mm	2,3880 mm
Pitch diameter max.	: 2,2655 mm	2,3185 mm
Pitch diameter min.	: 2,2585 mm	2,3115 mm
Minor diameter max.	: 2,0000 mm	2,0530 mm

Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	2,2631	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	2,3149	-

Valuation: usable

Operator:


 (Bantle)

Date: 27.02.2019

Uncertainty of measurement: $U = 2,5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.