

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 119624038
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996
Type of gauge : GO thread ring gauge (solid)
Thread designation : M 8x1.25-6e
Pitch : 1,2500 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC MSXP 100x25 Nr.551
Measurement traceability : Set of setting rings ID 8138 101590 D-K-15089-01-01 2016-09

Gauge nominal values

Major diameter min. : 8,0360 mm
Pitch diameter max. : 7,1300 mm
Pitch diameter min. : 7,1160 mm
Minor diameter max. : 6,5910 mm
Minor diameter min. : 6,5770 mm

Measuring values Pitch diameter

| Plane | Axial section | PitchØ [mm] | Out of tolerance [µm] |
|-------|---------------|-------------|-----------------------|
| 2 | 0 Degree | 7,1203 | - |

Valuation: usable

Operator:


(Buckenmayer)

Date: 22.03.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.