

## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 120042008  
**Gauge application** : Incoming inspection  
**Standard of thread** : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996  
**Type of gauge** : GO thread ring gauge (solid)  
**Thread designation** : M 4x0.35-6g  
**Pitch** : 0,3500 mm  
**Measuring method** : Inspection with checking or setting gauge

### Gauge nominal values

Major diameter min. : 4,0130 mm  
 Pitch diameter max. : 3,7610 mm  
 Pitch diameter min. : 3,7510 mm  
 Minor diameter max. : 3,6070 mm  
 Minor diameter min. : 3,5970 mm

### Checking the Pitch diameter with check plugs

Check plug	Check plug ID	PitchØ nominal value [mm]	PitchØ actual value [mm]
GO check plug	7533	3,7440 ±0,0035	3,7439
NOT GO check plug	5806	3,7610 ±0,0035	3,7628

**Valuation: usable**

Operator:

(Salvaggio)

Date: 01.03.2019

**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.