



## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 122418007  
**Gauge application** : Incoming inspection  
**Standard of thread** : Metric ISO threads acc. to ISO 965:1998/ISO 1502:1996  
**Type of gauge** : GO thread plug gauge  
**Thread designation** : M 48x5-6H  
**Pitch** : 5,0000 mm  
**Measuring method** : Three wires method  
**Wire diameter** : 3,2004 mm  
**Measuring force** : 4,50 N  
**Measurement traceability** : Zeiss ULM 600-C Nr.439  
**Measurement traceability** : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

### Gauge nominal values

**Major diameter max.** : 48,0420 mm  
**Major diameter min.** : 48,0060 mm  
**Pitch diameter max.** : 44,7850 mm  
**Pitch diameter min.** : 44,7670 mm  
**Minor diameter max.** : 41,8650 mm

### Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	44,7779	-

**Valuation: usable**

Operator:

*Eisele*  
(Eisele)

Date: 13.09.2019

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.