

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 122936016
Gauge application : Incoming inspection
Standard of thread : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : 10 (0.190) - 24 UNC -2B
Pitch : 1,0580 mm
Measuring method : Three wires method
Wire diameter : 0,6200 mm
second wire diameter : 0,6200 mm
Measuring force : 4,00 N
Measurement traceability : Mahr 828 Nr.22
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 4,8387 mm	4,7041 mm
Major diameter min.	: 4,8260 mm	4,6914 mm
Pitch diameter max.	: 4,1453 mm	4,2469 mm
Pitch diameter min.	: 4,1377 mm	4,2393 mm
Minor diameter max.	: 3,4493 mm	3,5509 mm

Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	4,1434	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	4,2433	-

Valuation: usable

Operator:


(Ammann)

Date: 13.11.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.