



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 123805009
Gauge application : Incoming inspection
Standard of thread : Unified insert thread acc. to factory standard
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : EG 10-24 UNC -2B
Pitch : 1,0580 mm
Measuring method : Three wires method
Wire diameter : 0,6200 mm
second wire diameter : 0,6200 mm
Measuring force : 4,10 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : single gauge ID 316275 014252 D-K-15048-01-00 2019-03

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 6,2140 mm	5,8210 mm
Major diameter min.	: 6,1960 mm	5,8030 mm
Pitch diameter max.	: 5,5225 mm	5,6055 mm
Pitch diameter min.	: 5,5135 mm	5,5965 mm
Minor diameter max.	: 4,7910 mm	4,8740 mm

Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	5,5187	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	5,6027	-

Valuation: usable

Operator:


(Ammann)

Date: 18.09.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.