

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 126218119
Gauge application : Incoming inspection
Standard of thread : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : 3/4 - 16 UNF -2B
Pitch : 1,5880 mm
Measuring method : Three wires method
Wire diameter : 0,8947 mm
second wire diameter : 0,8947 mm
Measuring force : 9,90 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 19,0652 mm	18,8722 mm
Major diameter min.	: 19,0500 mm	18,8570 mm
Pitch diameter max.	: 18,0264 mm	18,1839 mm
Pitch diameter min.	: 18,0188 mm	18,1762 mm
Minor diameter max.	: 16,9875 mm	17,1450 mm


Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	18,0217	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	18,1821	-

Valuation: usable

Operator: 
(Buckenmayer)

Date: 03.06.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.