

## CALIBRATION CERTIFICATE

Customer : 0155600  
 Identification number : 127124022  
 Gauge application : Incoming inspection  
 Standard of thread : Metric thread inserts acc. to DIN 8140:1999/2017  
 Type of gauge : GO/NOT GO thread plug gauge  
 Thread designation : EG M 6x1-6H mod  
 Pitch : 1,0000 mm  
 Measuring method : Three wires method  
 Wire diameter : 0,5766 mm  
 second wire diameter : 0,5766 mm  
 Measuring force : 3,40 N  
 Measurement traceability : Mahr 828 Nr.31  
 Measurement traceability : Parallelendmaß Nr.314950 033421 D-K-15048-01-00 2020-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 7,3150 mm	6,9560 mm
Major diameter min.	: 7,2970 mm	6,9380 mm
Pitch diameter max.	: 6,6605 mm	6,7515 mm
Pitch diameter min.	: 6,6515 mm	6,7425 mm
Minor diameter max.	: 6,0730 mm	6,1640 mm

### Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	6,6585	-

### Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	6,7480	-

Valuation: usable

Operator:

  
 (Buckenmayer)

Date: 10.06.2021

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.