



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 127448090
Gauge application : Incoming inspection
Standard of thread : Pipe threads according to ISO 228:2003
Type of gauge : NO GO thread ring gauge (solid)
Thread designation : G 1/8 A
Pitch : 0,9070 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC MSXP 100x25 Nr.551
Measurement traceability : Endmaßsatz Nr.3997 57308 D-K-15190-01-00 2015-06

Gauge nominal values


Major diameter min. : 9,7380 mm
Pitch diameter max. : 9,0400 mm
Pitch diameter min. : 9,0240 mm
Minor diameter max. : 8,8670 mm
Minor diameter min. : 8,8350 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	9,0266	-

Valuation: usable

Operator:


(Eha)

Date: 04.09.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.