

## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 128946032  
**Gauge application** : Incoming inspection  
**Standard of thread** : Pipe threads according to ISO 228:2003  
**Type of gauge** : GO thread ring gauge (solid)  
**Thread designation** : G 1 A  
**Pitch** : 2,3090 mm  
**Measuring method** : Measure with IAC Master Scanner  
**Measurement traceability** : IAC MSXP 100x60 Nr.598  
**Measurement traceability** : Set of setting rings ID 01-04150

### Gauge nominal values

**Major diameter min.** : 33,2490 mm  
**Pitch diameter max.** : 31,7710 mm  
**Pitch diameter min.** : 31,7510 mm  
**Minor diameter max.** : 30,2910 mm  
**Minor diameter min.** : 30,2710 mm

### Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	31,7604	-

**Valuation: usable**

Operator:

  
(Sahan)

Date: 28.02.2020

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:**  $(20 \pm 1) ^\circ\text{C}$ . **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.