

## CALIBRATION CERTIFICATE

Customer : 0155600  
Identification number : 132287007  
Gauge application : Incoming inspection  
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996  
Type of gauge : NO GO thread ring gauge (solid)  
Thread designation : M 35x1-6g  
Pitch : 1,0000 mm  
Measuring method : Measure with IAC Master Scanner  
Measurement traceability : IAC MSXP 100x60 Nr.598  
Measurement traceability : Set of setting rings ID 01-04150

**Gauge nominal values**

Major diameter min. : 34,9830 mm  
Pitch diameter max. : 34,1990 mm  
Pitch diameter min. : 34,1850 mm  
Minor diameter max. : 34,0060 mm  
Minor diameter min. : 33,9780 mm

**Measuring values Pitch diameter**

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	34,1947	-

**Valuation: usable**Operator:  Date: 27.01.2021

(Ammann-Mayer)

**Uncertainty of measurement:**  $U = 2,5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

**Ref.temp:**  $(20 \pm 1) ^\circ\text{C}$ . **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.