

## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 132428003  
**Gauge application** : Incoming inspection  
**Standard of thread** : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2  
**Type of gauge** : GO thread ring gauge (solid)  
**Thread designation** : 1 3/16 - 16 UN -2A  
**Pitch** : 1,5880 mm  
**Measuring method** : Measure with IAC Master Scanner  
**Measurement traceability** : IAC MSXP 100x60 Nr.598  
**Measurement traceability** : DAkkS Einstellringe im Satz Nr. 01-04150

### Gauge nominal values

**Major diameter min.** : 30,1244 mm  
**Pitch diameter max.** : 29,0932 mm  
**Pitch diameter min.** : 29,0855 mm  
**Minor diameter max.** : 28,4048 mm  
**Minor diameter min.** : 28,3896 mm

### Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	29,0909	-

**Valuation: usable**

Operator:

(Ammann)

Date: 21.10.2019

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

**Ref.temp:**  $(20 \pm 1) ^\circ\text{C}$ . **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.