



CALIBRATION CERTIFICATE

Customer : 0155600
 Identification number : 133307017
 Gauge application : Incoming inspection
 Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
 Type of gauge : GO thread ring gauge (solid)
 Thread designation : M 13x1-6g
 Pitch : 1,0000 mm
 Measuring method : Measure with IAC Master Scanner
 Measurement traceability : IAC MSXP 100x25 Nr.551
 Measurement traceability : Set of setting rings ID 01-04150

Gauge nominal values

Major diameter min. : 13,0550 mm
 Pitch diameter max. : 12,3290 mm
 Pitch diameter min. : 12,3150 mm
 Minor diameter max. : 11,8980 mm
 Minor diameter min. : 11,8840 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	12,3194	-

Valuation: usable

Operator:

ia
(Ammann)

Date: 20.11.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAKKS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref. temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.