



CALIBRATION CERTIFICATE

Customer : 0155600
 Identification number : 134695012
 Gauge application : Incoming inspection
 Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
 Type of gauge : GO/NOT GO thread plug gauge
 Thread designation : M 22x0.75-6H
 Pitch : 0,7500 mm
 Measuring method : Three wires method
 Wire diameter : 0,4553 mm
 second wire diameter : 0,4553 mm
 Measuring force : 4,10 N
 Measurement traceability : Mahr 828 Nr.31
 Measurement traceability : Parallelmaß Nr. 316275 014252 D-K-15048-01-00 2019-03

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 22,0230 mm	21,8195 mm
Major diameter min.	: 22,0010 mm	21,7975 mm
Pitch diameter max.	: 21,5305 mm	21,6640 mm
Pitch diameter min.	: 21,5195 mm	21,6530 mm
Minor diameter max.	: 21,0800 mm	21,0800 mm

Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	21,5230	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	21,6568	-

Valuation: usable

Operator:  Date: 31.10.2019
 (Buckenmayer)

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.

Ref.temp: $(20 \pm 1) ^\circ\text{C}$. Inspection requirement: The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.