



## CALIBRATION CERTIFICATE

Customer : 0155600  
 Identification number : 135662492  
 Gauge application : Incoming inspection  
 Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996  
 Type of gauge : GO/NOT GO thread plug gauge  
 Thread designation : M 5x0.8-6H  
 Pitch : 0,8000 mm  
 Measuring method : Three wires method  
 Wire diameter : 0,4553 mm  
 second wire diameter : 0,4553 mm  
 Measuring force : 4,00 N  
 Measurement traceability : Mahr 828 Nr.22  
 Measurement traceability : single gauge ID 316275 014252 D-K-15048-01-00 2019-03

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 5,0150 mm	4,7785 mm
Major diameter min.	: 4,9970 mm	4,7605 mm
Pitch diameter max.	: 4,4905 mm	4,6140 mm
Pitch diameter min.	: 4,4815 mm	4,6050 mm
Minor diameter max.	: 4,0190 mm	4,0190 mm

### Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	4,4874	-

### Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	4,6078	-

Valuation: usable

Operator:

(Ammann)

Date: 16.02.2022

Uncertainty of measurement:  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
 Ref.temp:  $(20 \pm 1) ^\circ\text{C}$ . **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.