



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 136153003
Gauge application : Incoming inspection
Standard of thread : Pipe threads according to ISO 228:2003
Type of gauge : NOGO thread plug gauge
Thread designation : G 3
Pitch : 2,3090 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC XLP-C 300 Nr.579
Measurement traceability : Set of setting plugs ID 02-04150

Gauge nominal values


Major diameter max. : 87,1080 mm
Major diameter min. : 87,0760 mm
Pitch diameter max. : 86,6380 mm
Pitch diameter min. : 86,6220 mm
Minor diameter max. : 84,7090 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	86,6335	-

Valuation: usable

Operator:


(Buckenmayer)

Date: 24.10.2019

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.