

## CALIBRATION CERTIFICATE

Customer : 0155600  
Identification number : 136651005  
Gauge application : Incoming inspection  
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996  
Type of gauge : NOGO thread plug gauge  
Thread designation : M 60x1-6H  
Pitch : 1,0000 mm  
Measuring method : Three wires method  
Wire diameter : 0,5770 mm  
Measuring force : 4,10 N  
Measurement traceability : Mahr 828 Nr.31  
Measurement traceability : Gauge block set ID 3997 57308 D-K-15190-01-00 2015-06

**Gauge nominal values**


Major diameter max. : 59,7465 mm  
Major diameter min. : 59,7245 mm  
Pitch diameter max. : 59,5410 mm  
Pitch diameter min. : 59,5300 mm  
Minor diameter max. : 58,7730 mm

**Measuring values Pitch diameter**

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	59,5336	-

**Valuation: usable**

Operator:

  
(Bantle)

Date: 01.10.2020

**Uncertainty of measurement:**  $U = 2,5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.