



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 138201007
Gauge application : Incoming inspection
Standard of thread : Unified threads acc. to ANSI/ASME B1.1-1989(R2001), B1.2
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : 11/16 - 16 UN -2B
Pitch : 1,5880 mm
Measuring method : Three wires method
Wire diameter : 0,8946 mm
second wire diameter : 0,8946 mm
Measuring force : 3,40 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : Parallelendmaß Nr.318378 069832 D-K-15048-01-00 2019-11

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 17,4777 mm	17,2771 mm
Major diameter min.	: 17,4625 mm	17,2618 mm
Pitch diameter max.	: 16,4389 mm	16,5887 mm
Pitch diameter min.	: 16,4313 mm	16,5811 mm
Minor diameter max.	: 15,4000 mm	15,5499 mm

Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	16,4326	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	16,5846	-

Valuation: usable

Operator:  Date: 01.02.2022
(Ammann-Mayer)

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.