

## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 138900039  
**Gauge application** : Incoming inspection  
**Standard of thread** : Unified insert thread acc. to factory standard  
**Type of gauge** : GO/NOT GO thread plug gauge  
**Thread designation** : EG 10-32 UNF -2B  
**Pitch** : 0,7940 mm  
**Measuring method** : Three wires method  
**Wire diameter** : 0,4553 mm  
**second wire diameter** : 0,4553 mm  
**Measuring force** : 4,10 N  
**Measurement traceability** : Mahr 828 Nr.31  
**Measurement traceability** : single gauge ID 316275 014252 D-K-15048-01-00 2019-03

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 5,8670 mm	5,5870 mm
Major diameter min.	: 5,8530 mm	5,5730 mm
Pitch diameter max.	: 5,3475 mm	5,4245 mm
Pitch diameter min.	: 5,3405 mm	5,4175 mm
Minor diameter max.	: 4,8770 mm	4,9540 mm

### Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	5,3439	-

### Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	5,4225	-

**Valuation: usable**

Operator:  Date: 04.06.2020  
 (Buckenmayer)

**Uncertainty of measurement:**  $U = 2,5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.