



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 139529002
Gauge application : Incoming inspection
Standard of thread : UNJ Aerospace threads acc. to ISO 3161:1999 (ASME B1.15)
Type of gauge : NO GO thread ring gauge (solid)
Thread designation : 3/8 - 24 UNJF -3A
Pitch : 1,0580 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC MSXP 100x25 Nr.551
Measurement traceability : Set of setting rings ID 01-04150

Gauge nominal values

Major diameter min. : 9,5250 mm
Pitch diameter max. : 8,7706 mm
Pitch diameter min. : 8,7630 mm
Minor diameter max. : 8,5471 mm
Minor diameter min. : 8,5344 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	8,7664	-

Valuation: usable

Operator:

i A
(Ammann-Mayer)

Date: 28.01.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.