

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 143263007
Gauge application : Incoming inspection
Standard of thread : Unified insert thread acc. to factory standard
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : EG 4-40 UNC -2B
Pitch : 0,6350 mm
Measuring method : Three wires method
Wire diameter : 0,3458 mm
second wire diameter : 0,3458 mm
Measuring force : 4,10 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : single gauge ID 316275 014252 D-K-15048-01-00 2019-03

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 3,6800 mm	3,4590 mm
Major diameter min.	: 3,6660 mm	3,4450 mm
Pitch diameter max.	: 3,2635 mm	3,3285 mm
Pitch diameter min.	: 3,2565 mm	3,3215 mm
Minor diameter max.	: 2,8500 mm	2,9150 mm

Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	3,2606	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	3,3263	-

Valuation: usable

Operator:


 (Bantle)

Date: 04.06.2020

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.