



## CALIBRATION CERTIFICATE

**Customer** : 0155600  
**Identification number** : 146097001  
**Gauge application** : Incoming inspection  
**Standard of thread** : Pipe threads according to ISO 228:2003  
**Type of gauge** : GO thread plug gauge  
**Thread designation** : G 2 1/4  
**Pitch** : 2,3090 mm  
**Measuring method** : Three wires method  
**Wire diameter** : 1,3023 mm  
**Measuring force** : 9,90 N  
**Measurement traceability** : Mahr 828 Nr.31  
**Measurement traceability** : Parallelendmaß Nr. 316275 014252 D-K-15048-01-00 2019-03

### Gauge nominal values

Major diameter max. : 65,7340 mm  
 Major diameter min. : 65,7020 mm  
 Pitch diameter max. : 64,2570 mm  
 Pitch diameter min. : 64,2410 mm  
 Minor diameter max. : 62,7520 mm

### Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	64,2502	-

**Valuation: usable**

Operator:

  
(Buckenmayer)

Date: 25.01.2022

**Uncertainty of measurement:**  $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$ . The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor  $k = 2$ . They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.  
**Ref.temp:** (20 ± 1) °C. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.