

CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 153885368
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : M 2x0.4-6H
Pitch : 0,4000 mm
Measuring method : Three wires method
Wire diameter : 0,2315 mm
second wire diameter : 0,2315 mm
Measuring force : 3,40 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : Parallelendmaß Nr.314950 033421 D-K-15048-01-00 2020-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 2,0150 mm	1,9235 mm
Major diameter min.	: 1,9970 mm	1,9055 mm
Pitch diameter max.	: 1,7505 mm	1,8390 mm
Pitch diameter min.	: 1,7415 mm	1,8300 mm
Minor diameter max.	: 1,5090 mm	1,5090 mm

Measuring values Pitch diameter - Go side


Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	1,7469	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	1,8351	-

Valuation: usable

Operator:


(Buckenmayer)

Date: 04.10.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.