



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 155277075
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : M 22x1.5-6H
Pitch : 1,5000 mm
Measuring method : Three wires method
Wire diameter : 0,8662 mm
second wire diameter : 0,8662 mm
Measuring force : 9,10 N
Measurement traceability : Mahr 828 Nr.31
Measurement traceability : Parallelendmaß Nr.314950 033421 D-K-15048-01-00 2020-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 22,0230 mm	21,5325 mm
Major diameter min.	: 22,0010 mm	21,5105 mm
Pitch diameter max.	: 21,0435 mm	21,2270 mm
Pitch diameter min.	: 21,0325 mm	21,2160 mm
Minor diameter max.	: 20,1590 mm	20,1590 mm

Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	21,0378	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	21,2188	-

Valuation: usable

Operator:


(Buckenmayer)

Date: 10.07.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.