



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 157300001
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
Type of gauge : GO/NOT GO thread plug gauge
Thread designation : M 20x0.75-6H
Pitch : 0,7500 mm
Measuring method : Three wires method
Wire diameter : 0,4553 mm
second wire diameter : 0,4553 mm
Measuring force : 4,50 N
Measurement traceability : Zeiss ULM 600-C Nr.439
Measurement traceability : single gauge ID 316275 033416 D-K-15048-01-00 2020-06

Gauge nominal values	Go side	Not Go side
Major diameter max.	: 20,0230 mm	19,8195 mm
Major diameter min.	: 20,0010 mm	19,7975 mm
Pitch diameter max.	: 19,5305 mm	19,6640 mm
Pitch diameter min.	: 19,5195 mm	19,6530 mm
Minor diameter max.	: 19,0800 mm	19,0800 mm


Measuring values Pitch diameter - Go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	19,5251	-

Measuring values Pitch diameter - Not go side

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	19,6558	-

Valuation: usable

Operator: 
(Gjigjani) Date: 25.02.2021

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.