



CALIBRATION CERTIFICATE

Customer : 0155600
Identification number : 160668034
Gauge application : Incoming inspection
Standard of thread : Metric ISO threads acc. to ISO 965:2013/ISO 1502:1996
Type of gauge : GO thread ring gauge (solid)
Thread designation : M 30x2-6g
Pitch : 2,0000 mm
Measuring method : Measure with IAC Master Scanner
Measurement traceability : IAC MSXP 100x60 Nr.598
Measurement traceability : Set of setting rings ID 01-04150

Gauge nominal values

Major diameter min. : 30,1170 mm
 Pitch diameter max. : 28,6640 mm
 Pitch diameter min. : 28,6460 mm
 Minor diameter max. : 27,8060 mm
 Minor diameter min. : 27,7880 mm

Measuring values Pitch diameter

Plane	Axial section	PitchØ [mm]	Out of tolerance [µm]
2	0 Degree	28,6546	-

Valuation: usable

Operator:  Date: 27.04.2021
(Ammann-Mayer)

Uncertainty of measurement: $U = 2.5 \mu\text{m} + 10 \cdot 10^{-6} \cdot d$. The uncertainty stated is the expanded uncertainty of measurement obtained by multiplying the standard uncertainty by the coverage factor $k = 2$. They were established according to DAkkS-DKD-3. The value of the measured variable is within the assigned value range with 95 % probability.
Ref.temp: $(20 \pm 1) ^\circ\text{C}$. **Inspection requirement:** The inspections procedure was based on recognised German inspection specifications (VDI/VDE/DGQ/2618). The measuring equipment and standards used are compared regularly with reference standards calibrated by a calibration service accredited by the European Cooperation for Accreditation (EA) and therefore traceable to the national standards of the PTB. Hence the inspection certificate complies with the traceability requirements of DIN EN ISO 9001.